

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

OSCAWANA
P985

OWNER	NAME SANTINO HOMES, INC.		ADDRESS Dahlia Drive, Mahopac, New York			
LOCATION OF WELL	Santino Court (No. & Street)		(Town)		(Lot Number) 3	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> PUBLIC SUPPLY		<input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> INDUSTRIAL		<input type="checkbox"/> FARM <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> TEST WELL <input type="checkbox"/> OTHER (Specify)	
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY <input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION		<input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)		795 H	
CASING DETAILS	LENGTH (feet) 46	DIAMETER (inches) 6	WEIGHT PER FOOT 17	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input type="checkbox"/> PUMPED <input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 4		G.P.M. 5	YIELD (G.P.M.) 5	
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 30		DURING YIELD TEST (feet) 300		Depth of Completed Well in feet below Land surface:	
SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) TO (feet)

[illegible]

DATE WELL COMPLETED
8/25/80

DATE OF REPORT
10/1/0

WELL DRILLER (Signature)

SANTINO COURT

Robert M. Mill

0.32